

REACTION TO FIRE

Applicant:

GABRIEL A/S

HJULMAGERVEJ, 55
DK-9000 Ålborg

Is authorized to place the label "Classification of Reaction to Fire of Construction Products" according to the 2024AN2937.



CLASSIFICATION OF REACTION TO FIRE OF: CONSTRUCTION PRODUCTS

Nº: 24AN2937

The sample referenced as:

"Amaze Loop"

has been tested according to the standards EN ISO 11925-2:2020 & EN 13823:2020 + A1:2022. The classification according to standard EN 13501-1:2018 is:

"B-s1,d0"

Date of Issue

26th of December 2024



Date: 26/12/2024 16:41:56

Digitally Signed by: DAVID MARSET GIMENO -

NIF: 21697288P

Joan Risueño
Head of Fire Behaviour lab.