



REACTION TO FIRE

Applicant:

GABRIEL A/S

HJULMAGERVEJ, 55
DK-9000 Ålborg

Is authorized to place the label "Classification of Reaction to Fire of Construction Products" according to the 2024AN0170.



CLASSIFICATION OF REACTION TO FIRE OF: CONSTRUCTION PRODUCTS

Nº: 24AN0170

The sample referenced as:

"Hush "

has been tested according to the standards EN ISO 11925-2:2020 and EN 13823:2020. The classification according to standard EN 13501-1:2018 is:

"B-s1,d0"

Date of Issue

31st of January 2024



Date: 31/01/2024 15:27:00

Digitally Signed by: DAVID MARSET GIMENO -

NIF: 21697288P

Joan Risueño
PPes Lab. Technician