



aitex[®]
research & innovation center

REACTION TO FIRE

Applicant:

GABRIEL A/S

HJULMAGERVEJ, 55
DK-9000 Ålborg

Is authorized to place the label "Classification of Reaction to Fire of Construction Products" according to the 2023AN2339.



CLASSIFICATION OF REACTION TO FIRE OF: CONSTRUCTION PRODUCTS

Nº: 23AN2339

The sample referenced as:

" Soul Melange 60182 Dark Grey"

has been tested according to the standards EN ISO 11925-2:2020 and EN 13823:2020. The classification according to standard EN 13501-1:2018 is:

"C-s1,d0"

Date of Issue

6rd of November 2023



Date: 06/11/2023 8:48:51

Digitally Signed by:DAVID MARSET GIMENO -

NIF:21697288P

Celia Dolça
Head of Fire Behaviour lab.