



**aitex**<sup>®</sup>  
research & innovation center

## REACTION TO FIRE

### Applicant:

GABRIEL A/S

HJULMAGERVEJ, 55  
DK-9000 Ålborg

Is authorized to place the label "Classification of Reaction to Fire of Construction Products" according to the 2022AN6660.



### CLASSIFICATION OF REACTION TO FIRE OF: CONSTRUCTION PRODUCTS

Nº: 22AN6660

The sample referenced as:

**"Lamina Laminated"**

has been tested according to the standards EN ISO 11925-2:2020 and EN 13823:2020. The classification according to standard EN 13501-1:2018 is:

**"B-s1,d0"**

Date of Issue

22nd of August 2022



**aitex**

Date: 22/08/2022 12:49:29

Digitally Signed by: DAVID MARSET GIMENO -

NIF: 21697288P

Celia Dolça  
Head of Fire Behaviour lab.